

Occupational Accidents Resulting in Injury or Death within the Premises of TEPCO's Fukushima Daiichi NPP (from 2014)

Number of deaths, injuries and diseases (requiring four or more days off) reported to the Tomioka Labor Standards Inspection Office doubled from four in 2013 to eight in 2014.

Date	Details of the accident	Remarks
Mar. 28, 2014	A worker was buried alive in a landslide during the repair work on the foundation piles of the warehouse.	Death
May 19, 2014	A worker slipped and fell while moving in the tank weir.	Serious injury
May 27, 2014	A worker slipped and fell while attempting to carry scaffolding pipes.	Serious injury
May 31, 2014	A worker fell while descending a swaying ladder.	Serious injury
Jun. 28, 2014	A worker slipped and fell from a temporary stairway and sprained an ankle.	Serious injury
Sep. 30, 2014	A worker received an electric shock while handling the end of a high-voltage cable.	Serious injury
Nov. 7, 2014	Workers were injured by a falling rolling ladder rail. ^(*)	Two serious injuries
Jan. 13, 2015	A worker hit his/her head against an iron plate which was being lifted.	Serious injury
Jan. 19, 2015	A worker fell while checking power sources for work (at Kashiwazaki Kariwa NPP).	Serious injury
Jan. 19, 2015	A worker fell from a manhole on the top of a tank.	Death
Jan. 20, 2015	Part of a machine that a worker was inspecting fell and the worker was caught by it (at Fukushima Daini NPP).	Death

Fatal accidents consecutively on two days



* An accident similar to that which occurred on November 7, 2014 (falling pipe) occurred on September 20, 2014 at the workplace of the same subcontractor.